Approved For Release 2002/01/02 : CIA-RDP78B04747A002100090044-2

Folder 991294

IPO/OSB/M-41-65
10 September 1965

MEMORANDUM FOR: Chief, Support Staff, NPIC

ATTENTION: Chief, Logistics Branch

SUBJECT: Environment of the [redacted] Fiber Optic Viewer 25X1

1. The P&DS installation survey initially stated a requirement for a one-micron particle size (clean room atmosphere) air conditioning capability for operation of the fiber optic. Since no mensuration capability is present in our instrument, the present ten-micron particle size of the air conditioning system is therefore adequate.

2. No action therefore is required to change the present air conditioning system.

[redacted] 25X1
Intelligence Production Officer, PAG

Distribution:
1 - Ch/SS/LB
2 - Addressee
1 - IPO/OSB/NPIC

DECLASS REVIEW by NIMA/DOD

GROUP 1
Excluded from automatic downgrading and declassification

Approved For Release 2002/01/02 : CIA-RDP78B04747A002100090044-2

Approved For Release 2002/01/02 : CIA-RDP78B04747A002100090044-2

NPIC ROUTING SLIP

FROM: C/Building Services Section

DATE: 15 Sept '65

	TO	INITIALS	DATE
DIR			
DEP/DIR			
EXEC/DIR			
ASST FOR ADMIN			
ASST FOR OPS			
ASST FOR PA			
[redacted]SST FOR P&D	x		
CH/CSD			
CH/IPD			
CH/PD			
CH/PSD			
CH/TID			
CH/CIA/PID			
CH/DIA/XX-4			
[redacted]H/DIA/AP-IP			
CH/SPAD			
LO/CGS/CIA			
LO/NSA			

REMARKS

STATINTL

STATINTL

ATTN: [redacted]

Are you aware that [redacted] is accepting a 10 micron particle size for this installation?

[redacted]

Comment

STATINTL

Approved For Release 2002/01/02 : CIA-RDP78B04747A002100090044-2